



Telephone: (517) 373-5383

Fax: (517) 373-1986

House Bill 4066 (Substitute H-1 as passed by the House) House Bill 4067 (Substitute H-1 as passed by the House)

Sponsor: Representative Julie Calley House Committee: Regulatory Reform

Ways and Means

Senate Committee: Regulatory Reform

Date Completed: 5-10-19

## **CONTENT**

House Bill 4066 (H-1) and House Bill 4067 (H-1) would amend the Fire Prevention Code and the Single State Construction Code Act, respectively, to specify that a school that had a vestibule would not have to install a manual fire alarm box within the vestibule if a manual fire alarm box were located within five feet of the vestibule's interior door.

Each bill would take effect 90 days after it was enacted.

Proposed MCL 29.3d (H.B. 4066) Proposed MCL 125.1504h (H.B. 4067) Legislative Analyst: Drew Krogulecki

## **FISCAL IMPACT**

The bills would have no fiscal impact on State or local government.

Fiscal Analyst: Elizabeth Raczkowski

## SAS\S1920\s4066sa

This analysis was prepared by nonpartisan Senate staff for use by the Senate in its deliberations and does not constitute an official statement of legislative intent.