## FUEL OIL (EXCERPT) Act 319 of 1929

## 125.569 Metal gauge.

Sec. 19. The metal used in all tanks shall be of a minimum gauge, U.S. standard, depending upon the capacity or size as given in the following table:

1 to 500 14 gauge   501 to 1100 12 gauge   1101 to 4000 7 gauge   4001 to 10500 1/4 inch   10501 to 20000 5/16 inch	Capacity	Thickness
501 to 1100 12 gauge   1101 to 4000 7 gauge   4001 to 10500 1/4 inch   10501 to 20000 5/16 inch	(Gallons)	of material
1101 to 4000 7 gauge 4001 to 10500 1/4 inch 10501 to 20000 5/16 inch	1 to 500	14 gauge
4001 to 10500 1/4 inch 10501 to 20000 5/16 inch	501 to 1100	12 gauge
10501 to 20000 5/16 inch	1101 to 4000	7 gauge
	4001 to 10500	1/4 inch
20001 to 30000 3/8 inch	10501 to 20000	5/16 inch
20001 to 30000 3/8 men	20001 to 30000	3/8 inch

History: 1929, Act 319, Imd. Eff. May 28, 1929;—CL 1929, 2626;—CL 1948, 125.569.