

**FIRE PREVENTION CODE (EXCERPT)**  
**Act 207 of 1941**

**29.5/ Unattended terminal at which tank filled by pipeline; high level alarm system.**

Sec. 5l. In addition to the requirements specified in section 5j, each unattended terminal at which a tank filled by pipeline is located shall comply with the following requirements:

(a) The high level alarm system shall be capable of systematically shutting off or diverting the flow of the flammable liquid at the point of origin or at the point of receipt.

(b) The high level alarm system shall be capable of systematically shutting off or diverting the flow of the flammable liquid, in the event of a power failure at the point of origin or at the point of receipt.

**History:** Add. 1981, Act 186, Imd. Eff. Dec. 23, 1981.

**Compiler's note:** For transfer of certain authority, powers, functions, and responsibilities of the state fire marshal and the fire marshal division of the department of state police to the director of the department of labor and economic growth, bureau of construction codes and fire safety, by type II transfer, see E.R.O. No. 2003-1, compiled at MCL 445.2011.

For transfer of powers and duties of the department of environmental quality under the aboveground storage tank program from department of environmental quality to bureau of fire services, department of licensing and regulatory affairs, see E.R.O. No. 2012-7, compiled at MCL 29.462.