

**FIRE PREVENTION CODE (EXCERPT)**  
**Act 207 of 1941**

**29.5n Delivery of flammable liquid into above ground liquid storage tank by pipeline at remote control terminal; conditions.**

Sec. 5n. A firm shall not deliver a flammable liquid that has a flash point below 100 degrees Fahrenheit directly into an above ground liquid storage tank by pipeline at a remote control terminal unless the firm does each of the following:

(a) Furnishes to the director of the department of environmental quality, and receives the approval from the director of the department of environmental quality of, a detailed description of the firm's capabilities and procedures to deliver a flammable liquid by remote control to an above ground liquid storage tank.

(b) Furnishes to the director of the department of environmental quality, and receives the approval from the director of the department of environmental quality of, a description of the firm's procedures to be followed if an above ground storage tank is overfilled.

**History:** Add. 1981, Act 186, Imd. Eff. Dec. 23, 1981;—Am. 2006, Act 189, Imd. Eff. June 19, 2006.

**Compiler's note:** For transfer of certain authority, powers, functions, and responsibilities of the state fire marshal and the fire marshal division of the department of state police to the director of the department of labor and economic growth, bureau of construction codes and fire safety, by type II transfer, see E.R.O. No. 2003-1, compiled at MCL 445.2011.

For transfer of powers and duties of department of environmental quality to department of natural resources and environment, see E.R.O. No. 2009-31, compiled at MCL 324.99919.

For transfer of powers and duties of the department of environmental quality under the aboveground storage tank program from department of environmental quality to bureau of fire services, department of licensing and regulatory affairs, see E.R.O. No. 2012-7, compiled at MCL 29.462.