

MOTOR FUELS QUALITY ACT (EXCERPT)
Act 44 of 1984

290.644a Testing storage tank at retail outlet to determine water or water-alcohol level; prohibited sales; testing supplies.

Sec. 4a. (1) A storage tank at a retail outlet shall be periodically tested by the retail dealer to insure that the tank does not have water or water-alcohol at the bottom of that tank in an amount greater than 2 inches. If there is more than 2 inches of water or water-alcohol at the bottom of the storage tank, gasoline, diesel fuel, biodiesel, or biodiesel blend shall not be sold to a consumer from that tank until the water or water-alcohol level is reduced to a level of less than 2 inches.

(2) Adequate testing supplies, as determined by the department, shall be maintained at the retail outlet and shall also be made available to the department to determine the water or water-alcohol level in the storage tank.

History: Add. 1986, Act 127, Eff. Aug. 1, 1986;—Am. 2002, Act 13, Imd. Eff. Feb. 19, 2002;—Am. 2002, Act 425, Imd. Eff. June 5, 2002;—Am. 2006, Act 271, Imd. Eff. July 7, 2006.

Compiler's note: For transfer of powers and duties relating to purity and quality standards for biofuels from department of energy, labor, and economic growth to department of agriculture, see E.R.O. No. 2009-4, compiled at MCL 445.2026.